



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION IX
75 Hawthorne Street
San Francisco, CA 94105-3901

Wednesday, March 18, 2015

Craig Andrews, Mishongnovi Board of Directors
Mishongnovi Village
c/o Hopi Tribe P.O. Box 123
Kykotsmovi, AZ 96039

REPORT OF VIOLATIONS OF THE SAFE DRINKING WATER ACT

Dear Mr. Andrews:

This letter is to notify you of violations of the Safe Drinking Water Act (SDWA) and what must be done to correct the violations for the public water system (PWS) shown below:

Mishongnovi (Upper Sipaulovi/Upper Mishongnovi), PWS ID#0400394

The violations reported by EPA Region 9 to EPA HQ for the period ending on 12/31/2014 can be found on the attached table.

Public Notification Requirements

The public must be notified any time there is a violation of the SDWA. Depending on the severity of the violation, the type of Public Notice required will fall into one of three "tiers." The final column of the table labeled "Public Notice Tier" indicated the type of Public Notice required for the associated violation. If this PWS is required to distribute an annual Consumer Confidence Report, the Tier 3 notifications can be included in that report. Public Notice templates and handbook can be obtained by request from EPA or can be found at:

<http://water.epa.gov/lawsregs/rulesregs/sdwa/publicnotification/compliancehelp.cfm>

Tier 1 violations require notification within 24 hours.

Tier 2 violations allow 30 days for notification.

Tier 3 violations require annual notification.

Failure to comply with the public notice requirement will result in further violations.


Return to Compliance

EPA determines that the drinking water system has returned to compliance when the system reports the required sample results, or corrects the violation appropriately. An official Return to Compliance (RTC) will be entered into our records at that point. All violations and RTCs are reported to the EPA website, see: http://www.epa-echo.gov/echo/compliance_report_sdwa.html

Violations of the SDWA that are not corrected lead to a PWS being designated as an 'Enforcement Priority', as identified on EPA's national Enforcement Targeting Tool list. Drinking water systems that acquire this designation are targeted priorities for possible enforcement action by EPA. Furthermore, Enforcement Priority status precludes eligibility for funding under our infrastructure program, unless the proposed project will bring the system into compliance.

If your system has returned to compliance including the requirement to provide public notice, no further action is necessary. If you have questions regarding this matter, please contact Bessie Lee of my staff at (415) 972-3776.

Sincerely,

A handwritten signature in black ink, appearing to read 'D Albright', with a stylized flourish at the end.

David Albright, Manager
Drinking Water Protection Section

cc: Herman Honanie, Chairman
Mitchell Sockyma, Water Operator
Sherilyn Honanie, Acting CSA
Patrick Thompson, Water Operator
Lionel Puhuyesva, Director, WRP

Mishongnovi (Upper Sipaulovi/Upper Mishongnovi), PWS ID#0400394**Table of Violations reported by EPA Region 9 to EPA Headquarters for period ending 12/31/2014**

Violation Type: Failure to submit Followup and Routine Sampling results for Lead and Copper Rule.

<u>Contaminant</u>	<u>Violation Period*</u>	<u>Sample Date</u>	<u>Result</u>	<u>Violation Comment +</u>	<u>Public Notice Tier</u>
Lead and Copper Rule	1/1/2014 12/31/2014	N/A	N/A	Failed to monitor and/or report required Lead and Copper monitoring results due annually. Lead	3

The Water System must do the following: Report monitoring results as required.

* Depending on the contaminant and your public water system's monitoring schedule, violations are reported in the quarter following the due date.

+ The comment field indicates the reason for the violation and may indicate whether the system has corrected the violation, issued public notice, or remains out of compliance.

